



HOW TO SPECIFY 2200 Small Service Pillars

Feeder Pillars should be as Pudsey Diamond 2200 series or similar approved and should be manufactured from 3mm mild steel and hot dip galvanised after manufacture to BS EN ISO 1461. Root section is integral type. Doors are close fitting hinged folded steel type with return strengthening flanges all round. The door frame is fitted with a heavy duty non perishable automotive IP54 gasket. Locks are stainless steel with captive stainless steel recessed pin lock assemblies with stainless steel cover plugs and are to allow the lock types to be interchangeable. Door hinges are Heavy duty stainless steel and phosphor bronze block hinges with "Lube for Life" Dry Lubrication System and configured in such a way that the side wall cut out minimises entrapment. The door should have an embedded durable hazard warning sign affixed thereto, all to comply with the Health & Safety (Safety Signs & Signals) Regulations & the Electricity at Work Regulations. The backboard should consist of thick exterior ply board, 12mm thickness treated with preservative after cutting to shape.